



A P P R O V A L S ®

Certificate of Conformity

Certificate No.: SAA-181918-EA

Certificate Holder: Citisolar QLD Pty Ltd As Trustee For
PGK Distributors Unit Trust t/as
PGK Distribution
8 Mohr Street
Tullamarine VIC 3043
Australia

Class Description: DC Isolator
Product Description: PV Switch-disconnector

Brand Name:



Model No.:

SE030C

Markings:

1200Vdc (Ie=13, 32A),
1000Vdc (Ie=13, 32A),
800Vdc (Ie=32, 45A),
600Vdc (Ie=32, 50A)
Ta: -40°C to +85°C, DC-PV2, IP66NW

Standard:

AS 60947.3:2018
AS/NZS IEC 60947.1:2015

Conditions:

Nil

Approval Mark:

SAA-181918-EA or RCM

Date First Registered:

16 July 2018

Date of Expiry:

16 July 2023

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 16-07-18 181918/1

www.jas-anz.org/register



A P P R O V A L S ®

Certificate of Conformity

* Addendum *

Certificate No.: SAA-181918-EA

Date of Issue: 16 July 2018

Class Description: DC Isolator

Product Description: PV Switch-disconnector

Additional Models

Description

SE030D	Similar to SE030C except PV-connector and common MC4.
SE030F	Similar to SE030D except PV-connector and common MC4.
SE042F	Similar to SE030F except for model number.
SE030N	Similar to SE030C except for panel mounting and without enclosure (IP20).
SE030M	Similar to SE030C except for DIN rail mounting and without enclosure (IP20).

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 16-07-18 181918/2

www.jas-anz.org/register



A P P R O V A L S ®

Certificate of Conformity

Addendum

Certificate No.: SAA-181918-EA

Date of Issue: 23 July 2018

Class Description: DC Isolator

Product Description: PV Switch-disconnector

Additional Models

SE042D

Description

Similar to SE030F except for model number.

A handwritten signature in black ink, appearing to be 'SAA', positioned above a horizontal line.

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 23-07-18 181918/3



A P P R O V A L S ®

Certificate of Conformity

* Addendum *

Certificate No.: SAA-181918-EA

Date of Issue: 5 March 2019

Class Description: DC Isolator

Product Description: PV Switch-disconnector

General Modification:

For models SE030C, SE030D, SE030F, SE042F, SE030N, SE030M and SE042D:

Rating reduced from:-

1200Vdc (Ie=13, 32A), 1000Vdc (Ie=13, 32A), 800Vdc (Ie=32, 45A), 600Vdc (Ie=32, 50A); to
1200Vdc (Ie=9, 32A), 1000Vdc (Ie=9, 32A), 800Vdc (Ie=13, 32A), 600Vdc (Ie=32, 40A), 300Vdc (Ie=32, 45A).

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



Issued: 05-03-19 181918/4

www.jas-anz.org/register



A P P R O V A L S ®

Certificate of Conformity

* Addendum *

Certificate No.: SAA-181918-EA

Date of Issue: 23 May 2019

Class Description: DC Isolator

Product Description: PV Switch-disconnector

General Modification:

Addition of breathing valve as per recommendation of CEC guideline Clause 7.9.5.

Additional Models	Description
SE042I	Similar to SE030F except for model number.

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 23-05-19 181918/5

www.jas-anz.org/register